



CONFORMANCE

August 4, 2023

Gary Howe
Gbhowe92@aol.com

RE: Authorization for transfer of property at 588 Joan Mason, MI 48854, Alaieton Township, Section 31, Parcel 33-06-06-31-377-020, POS 8402-07-28-23

Dear Mr. Howe:

On July 28, 2023, this office reviewed an inspection report from certified inspector, Casey Fiedler, regarding the construction and functional status of the onsite water supply and/or sewage treatment systems located at the above referenced property. On August 4, 2023, this office received confirmation that the well casing was extended to 12 inches above grade.

Based on the information contained in the report and subsequent documentation received, this office has determined that the systems inspected are in substantial conformance with the "Ingham County Regulation for the Inspection of Onsite Water Supply and Sewage Disposal Systems at Time of Property Transfer". The property is authorized for transfer.

This **AUTHORIZATION** is valid for one year and does not imply that the system(s) meet the current construction standards. This authorization does not imply or express any warranty or guarantee as to the future function and suitability of the inspected system(s). The evaluation was performed based on the past use of the system(s). Any change in future use may change the operational status of the inspected system(s).

If the property has not transferred within one year, our office requests that you contact us regarding a possible extension. An extension will require a follow-up inspection by a representative from this office.

The following items were identified as actions that could be taken to extend the life of the system(s) or are of concern however, the system(s) are in substantial conformance with the above-mentioned regulation and no repairs are required:

Environmental Health

Mr. Howe
August 4, 2023
Page 2

RECOMMENDATONS

1. The Environmental Health Department recommends pumping out the septic tanks every 5 to 6 years. Property owners have full responsibility for upkeep, maintenance and repair of their septic system.
2. It is recommended that you have your water supply system tested every two years for a routine bacteriological and partial chemistry test. You may contact Ingham County Environmental Health at (517) 887-4312 for bottles.
3. This office recommends the installation of a hose-bib vacuum breaker on any threaded spigot connected to the water supply system.
4. It is encouraged that all owners of the subject property maintain a copy of this **AUTHORIZATION** with other important home records.

Any questions regarding this letter should be directed to the Ingham County Environmental Health Department at (517) 887-4312.

Sincerely,



Meredith Gregory, REHS
Land and Water Supervisor
Ingham County Health Department
MGregory@ingham.org

Environmental Health