



Mark C. Pope Associates, Inc. 4910 Martin Court Smyrna, GA 30082 800-299-2999, info@markcope.com	<b>Sender:</b>	<b>ITW GSE 4400 Information</b>
	<b>Company:</b>	<b>Model:</b>
	<b>Fax:</b>	<b>Serial No.:</b>
	<b>Phone:</b>	<b>Error Code:</b>
	<b>Contact:</b>	<b>Date:</b>
	<b>E-mail:</b>	<b>Time:</b>

**How to retrieve parameters from the Black Box :**

1. Press centre button  hold it down for approximately 10 seconds to enter the Icon Menu.
2. To select Black Box, simply use the navigation keys ◀▼▲▶ to highlight the icon  Then press the ● to enter the menu
3. Use the ▼/▲ to highlight the failure you want to view
4. Press ● to select View information on the error. The error is then explained in clear text
5. Press ● to view detailed Alarm Data
6. Use the ▼/▲ to browse through the recorded data
7. Use ◀ to leave the submenu
8. Use ◀ to leave the submenu and return to basic Icon Menu

<b>Output voltage:</b>	<b>A:</b> V	<b>B:</b> V	<b>C:</b> V	<b>Average:</b> V
<b>Output current:</b>	<b>A:</b> A	<b>B:</b> A	<b>C:</b> A	<b>Average:</b> A
<b>28VDC Output (option):</b>	Voltage: V	Current: A	Ripple: V	<b>Hour Meter:</b>
<b>Interlock 1 Level:</b>	V	Ripple: V	<b>ENGINE STATUS:</b>	
<b>Interlock 2 Level:</b>	V	Ripple: V		
<b>Control DC Voltage:</b>	V	<b>Generator Duty Cycle:</b>		
<b>Engine RPM:</b>	<b>Oil Pressure:</b>	<b>Engine Temp:</b>		
<b>Engine Load:</b>	<b>Fuel Level:</b>	<b>DEF (T4):</b>		
<b>WARNINGS (Other indication (lamps, LED's, damages of enclosure etc.):</b>				