

Primary applications for Ross WSFV-05 and WSFV-15R Security Windows include government, industrial, commercial and residential properties where protection of people and property is of utmost concern and where forced entry, ballistic and blast threats are present singularly or in combination; where conformance to U.S. Department of State forced-entry and ballistic threat levels is required; and where aesthetic, architectural or security concerns require the use of a large window or ganged window systems. For more information, please call our toll-free number above or visit our website.

Ross WSFV-05 and WSFV-15R Security Windows can be installed as single unit or ganged together in a "window wall". They are tested to either 5 or 15 minutes of simulated "mob" forced-entry attack in multiple window locations, and resistant to 5.56 M193 & M855, plus 7.62 M80 ballistic rounds (15 minute FE/BR units). Ross security windows can be engineered to resist blast loads up to and beyond 40 psi / 300 psi-ms, with "no hazard" rating. High strength, structural steel construction allows for narrower sightlines than aluminum windows. Optional, easily installed interior trim and exterior trim allows for both installation flexibility and a wide range of finish types. The widespread acceptance and success of our products stem from Ross' test-proven designs and extremely high level of manufacturing quality.

SECTION 085657

SECURITY WINDOWS

(ROSS WSFV-05 AND WSFV-15R STEEL SECURITY WINDOWS)

PART 1 - GENERAL

1.1 SUMMARY

- A. Work Included: Provide labor, materials and equipment necessary to complete the work of this Section, including but not limited to the following:
 - 1. Factory-glazed steel security windows.

1.2 SUBMITTALS

- A. Product Data: Submit manufacturer's product data for each type of product.
- B. Shop Drawings: Submit shop drawings including the following:
 - 1. Complete list of materials and manufacturer's descriptive and technical literature.
 - 2. Proposed layout, details of construction and anchorage and relationship to other parts of the work.
 - 3. Manufacturer's certification of security performance.
- C. Warranty: Submit executed copy of manufacturer's standard limited warranty.

1.3 QUALITY ASSURANCE

- A. Installer: Minimum 2 year documented history of installing similar windows and acceptable to the manufacturer. Installer shall accept responsibility for all field verifications.
- B. Manufacturing Facility: Certified to ISO 9001: 2015.

1.4 DELIVERY, STORAGE AND HANDLING

- A. Store materials in a location protected from the weather, humidity, temperature variation, dirt and dust, or other contaminants.

1.5 WARRANTY

- A. Warranty: Provide manufacturer's standard limited 5-year warranty.

PART 2 - PRODUCTS

2.1 MANUFACTURER

- A. Basis-of-Design Manufacturer: Ross Technology Corporation, 104 North Maple Avenue, Leola, PA 17540. Toll-free 800-345-8170. www.rosstechnology.com. No substitutions.

2.2 SECURITY WINDOWS

- A. Security Windows: Steel Security Windows by Ross Technology Corporation complying with the following:
 - 1. Model WSFV-05:
 - a. Forced Entry Resistance: 5 minutes per DOS SD-STD-01.01 Rev G (Amended).
 - b. DOS Code: 1141.
 - 2. Model WSFV-15R:
 - a. Ballistic Resistance: 5.56 M193, 5.56 M855, 7.62 M80 per DOS SD-STD-01.01 Rev G (Amended). UL 752 level 5 ballistic resistance per project requirements. Ballistic stop bars to protect construction shim gap.
 - b. Forced Entry Resistance: 15 minutes per DOS SD-STD-01.01 Rev G (Amended).
 - c. DOS Code: 1123.
 - d. Blast Resistance: Engineered to project requirements.
 - 3. Frame Construction: Welded steel frame with mitered corners and drain holes with exterior weep slots and removable glazing stops.
 - a. Frame Depth (without trim): 6.0 inches.
 - b. Frame Profile Width: 2.38 inches.
 - c. Mounting Technique: M12 or larger bolts, maximum 12 inches on center.
 - 4. Performance:
 - a. Air Leakage, ASTM E283, 1.6 psf: Less than 0.01 cfm/ft.
 - b. Water Penetration, ASTM E331/E547, 20 psf: Pass.
 - c. Dynamic Water Penetration, AAMA 501.1, 10 psf: Pass.
 - d. Uniform Load Deflection, ASTM E330, +91 psf / -115 psf: Less than 0.01 inch.
 - e. Uniform Load Structural, ASTM E330, +136 psf / -173 psf: Less than 0.01 inch.
 - f. Thermal Cycling, AAMA 501.5, 1.6 psf air: 0.01 cfm/sqft; 6.2 psf air: 0.04 cfm/sqft; 15 psf water: Pass.
 - g. Thermal U-factor, SHGC, CR, VLT, analyzed per NFRC 100, 200, 500; results vary with glazing type.

5. Window System Components: (optional)
 - a. Transaction tray (certified as 15 minute FE/BR) with interior lid and stainless steel interior/exterior trim.
 - b. Transaction drawer (certified as 15 minute FE/BR) with interior lid and stainless steel interior/exterior trim.
 - c. Snap-on interior window trim.
 - d. Exterior window trim.
 - e. Blast-rated glazing and anchorage systems (user-defined blast loads).
 - f. Sub-frames for installation, pre-drilled and tapped plate-type embeds.
 - g. Sub-frames for installation, pre-drilled and tapped tube-type frames.
6. Glazing: Engineered to project requirements. (optional glazing:)
 - a. Low-e hardcoats.
 - b. Films for RF / IR attenuation.
 - c. Tints.
 - d. Frits.
 - e. High-definition printing.
 - f. Switchable privacy glass.
7. Finish for Frame and Glazing Stops:
 - a. Hot-dip galvanized, ASTM A123. (standard).
 - b. Epoxy primed.
 - c. Epoxy primed and manufacturer's standard powder coat. (contact Ross for color chart and minimum quantities)
8. Finish for Interior/Exterior Trim:
 - a. Primer and finish coat. (standard, contact Ross for color chart)
 - b. Clear anodizing, 204-R1 or 215-R1.
 - c. Color anodizing.
 - d. Painted finish, AAMA 2604. (contact Ross for color chart and minimum quantities)
 - e. Painted finish, AAMA 2605. (contact Ross for color chart and minimum quantities)
 - f. Stainless steel cladding.

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Examine substrates and site conditions for compliance with requirements for installation tolerances and other conditions affecting performance. Proceed with installation only after unsatisfactory conditions have been corrected.

3.2 INSTALLATION

- A. Install products in strict accordance with manufacturer's instructions and approved submittals. Locate security windows level, plumb, and in proper alignment with adjacent work. Provide installation method suitable for substrate and project conditions:
 1. Pre-drilled and tapped plate-type embeds cast into concrete.
 2. Pre-drilled and tapped steel tube-type sub-frames bolted into the wall.
 3. Pre-drilled and tapped steel tube-type sub-frames welded to the wall structure.

- B. Protect adjacent areas against damage; repair or patch damaged areas. Restore damaged finishes so no evidence remains of corrective work.

3.3 ADJUSTING AND CLEANING

- A. Clean exposed surfaces using methods acceptable to the manufacturer which will not damage finish.

END OF SECTION

REV 0218 SK